

**UV Advanced Oxidation Treatment,
Jim Blanchard & Clarks Hill WTP
Bid# 2021008-BID5100**

Addendum #4

This addendum forms a part of the Contract Documents and modifies the original drawings and specifications. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

SPECIFICATION 15100 VALVES, COCKS AND HYDRANTS

Page 15100, 2.3.C.3

ADD Motorized actuators shall be 480 Volt/3 phase and modulating. Motorized actuators shall be equipped with limit switches to indicate fully open or fully closed. Motorized actuators shall provide analog output indicating percent open. Motorized actuators shall be Auma, EIM, or Limitorque.

Dwg 3M2

Valve Schedule **ADD** "Modulating" in Remarks box for valves V6 and V8.

Dwg 4M2

Valve Schedule **CHANGE** Valve Type from GV to BV (Butterfly Valve) for valves V9 through V13.

END OF ADDENDUM