



Bid Package 02.01 Tunnel and Shafts Addendum 1

Contract Attachments:

The following attachments are supplementary to this bid or replace previously included documents. All bidders should assume that this bid package will be a new contract for this project. This addendum and related attachments can be found at the link provided with the bid documents “Addenda”.

- **Attachment 03 – Subcontract Terms and Conditions**
- **Attachment 04 – Peachtree Drop Shaft Rock Profile**
- **Attachment 05 – Sample Insurance Certificate**
- **Attachment 06 – City of Atlanta E-Verify FORM 1**
- **Attachment 07 – COA WS Phase 1 RFP pdf (1) OCC Requirements**
- **Attachment 08 – E018b Policy Regarding Discrimination and Harassment**
- **Attachment 09 – P080 Design-Build Rider**
- **Attachment 10 – P220A.PC-Russell JV Subcontractor Safety Agreement**
- **Attachment 11 – P230GA.PC-Russell JV Waiver of Lien and Release Upon Final Payment - GA**
- **Attachment 12 - P232GA.PC-Russell JV Interim Waiver of Lien and Release of Claim-GA**
- **Attachment 13 – P350.PC-Russell JV Subcontract Performance Bond**
- **Attachment 14 - Prism New Format Subcontractors**
- **Attachment 15 - SF060.PC-Russell JV Safety Questionnaire-Echosign**
- **Attachment 16 - SF060.Subcontractor Safety and Health Questionnaire (1)**
- **Attachment 17 - ST-12 Rev 11-12**

Additional/Supplemental Information/Q&A Responses:

- 1) Attachment 04 – Peachtree Drop Shaft Rock Profile has been provided along with several photos of the construction of this shaft to assist bidders with understanding where PWR and rock were encountered. Additionally, in Addendum 2 of the Chattahoochee River Intake Pump Station Bid (provided in this package) a boring was provided near the vicinity of the far end of the tunnel. This boring encountered PWR at elevation 787’ and refusal at 785’.
- 2) Site restoration of this work area will be required at the completion of work. It should be assumed that all roads will be repaired if damaged, erosion control and temporary measures removed and final site grading and seeding to grow grass will be completed by this subcontractor.
- 3) Payment & Performance Bond must be included as part of this proposal.
- 4) It shall be assumed that SOE utilized for installation of the “launch” shaft can be left in place except for the top 8’ which must be removed and disposed of by this subcontractor.

5) Bid Form – Rev1 has been included. This bid form must be filled out to be deemed a responsive bidder.