



## DAVIS & BROWN

ENGINEERING • ENVIRONMENTAL • O&M SERVICES

www.NACCDB.com

(843)665-6746 (843)629-1444 Fax

Project: East Broad Street Sewer Replacement  
Owner: City of Darlington

RIA #R-20-1244  
DB2020-303

### ADDENDUM #1

Find attached a revised Bid Form reflecting the following revision:

1. Added Division 2 of the Bid Schedule for the cost of a temporary bury of the existing 8" HDPE sewer bypass piping at the intersection of 4th Street and E. Broad Street. A construction detail was added of this on sheet 8 of 9 of the plans. **Use the attached revised "Bid Form"**.

Find attached a revised set of plans reflecting the following revisions:

1. Revised construction detail on sheet 8 of 9 of the plans to specify DR 26 PVC pipe in depths  $\geq 12'$  and DR 35 PVC pipe in depths  $< 12'$ .
2. Changed construction detail title on sheet 5 of 9 of the plans, "Sewer Pipe Bedding Detail".
3. Added existing RCP designation to profile on sheet 4 of 9 of the plans.

This information will be emailed to each plan holder.

**THIS ADDENDUM SHOULD BE ACKNOWLEDGED ON THE APPROPRIATE PAGE OF THE BID FORM.**

Issued Aug. 3, 2020.  
9:30 am

Submitted by:  
Glenn T. Kirven PE