



- NOTES:**
- BULK TANK FILL STATION SHALL INCLUDE DRIP CONTAINMENT, DIGITAL LEVEL INDICATOR WITH HIGH LEVEL AND HIGH-HIGH LEVEL ALARMS AND A HORN AND SIREN WITH ALARM SILENCE PUSH BUTTON.
 - CORROSION INHIBITOR FEED PIPING LOCATED OUTSIDE OF CONTAINMENT AREAS SHALL BE INSTALLED WITH DOUBLE CONTAINMENT AND LEAK DETECTION.
 - CONTAINMENT AREA FLOORS SHALL BE SLOPED TO SUMPS.
 - MAKE-UP WATER SUPPLY PROVIDED FOR FLUSHING THE CHEMICAL FEED LINES.

10/17/2014 3:46:45 PM P:\ER\11740\200-11740-10003\CAD\SHEETFILES\TREATMENT PLANT\WTP-D-00X\PROCESS FLOW DIAGRAMS.DWG EVANS, JON

TETRA TECH
www.tetrattech.com
101 QUALITY CIRCLE, SUITE 140
HUNTSVILLE, ALABAMA 35806
PHONE: (256) 424-4077 FAX: (256) 424-4097

BID SET

MARK	DATE	DESCRIPTION	BY

HUNTSVILLE UTILITIES
SOUTHEAST WATER TREATMENT PLANT
**CORROSION INHIBITOR
FEED SYSTEM PROCESS
PIPING SCHEMATIC**

Project No.: 200-11740-10003
Designed By: JCB
Drawn By: JTE
Checked By: JEC

D-2116
Copyright: Tetra Tech
Bar Measures 1 inch