

BID SET


MARK	DATE	DESCRIPTION	BY

HUNTSVILLE UTILITIES
SOUTHEAST WATER TREATMENT PLANT
ELECTRICAL PLAN -
SITE SECTION B

Project No.: 200-11740-10003
Designed By: CSW
Drawn By: TAC
Checked By: DAB

E-0103

Bar Measures 1 inch



- 4" (72-STRAND MM FIBER), WTP-PP-5A TO WTP-PP-2C
- 4" (48-STRAND MM FIBER), WTP-PP-5B TO WTP-PP-2B
- 4" (PULL-STRING), SPARE
- 4" (20#14, PULL-STRING), A2-8 TO WTP-RCP-2
- 4" (PULL-STRING) FOR SECURITY
- 6" (3#1/0, 1#6, PULL-STRING), MCC-A2 TO PP-A2
- 6" (3#12, PULL-STRING), A2-8 TO PP-A2
- 6" (PULL-STRING), SPARE
- 6" (PULL-STRING), SPARE

- NOTES:**
- CONDUIT AND WIRE FROM WASHWATER STORAGE TANK TO RECOVERY BASIN EQUIPMENT SHALL BE ROUTED BACK TO BUILDING THROUGH HH-61 AND HH-62.
 - SEE SCHEMATIC ON SHEET E-0603 FOR FIBER PANEL CONSTRUCTION.
 - PROVIDE 24" SEPARATION BETWEEN POWER AND CONTROLS/INSTRUMENTATION CONDUITS.

PLAN
SCALE: 1"=20'

10/17/2014 10:50:51 AM P:\IER\11740\200-11740-10003\CAD\SHEETFILES\TREATMENT PLANT\WTP-E-0102-E-0106 ELECTRICAL SITE PLAN SECTIONS.DWG CALZARETTA, TIMOTHY