



PLAN
SCALE: 3/16"=1'-0"

- KEYED NOTES:**
- 1 PROVIDE 120VAC, 20AMP SPECIFICATION GRADE RECEPTACLE, BOX, STRUT AND FASTENERS AT EACH RADIANT HEATER BLOWER FOR CORD AND PLUG CONNECTION.
 - 2 PROVIDE CONDUIT AND CONTROL WIRING PER VENDOR WIRING DIAGRAM FOR AUTOMATIC EXERCISING AND TRANSFER.
 - 3 COORDINATE LOCATION OF TAMPER AND FLOW FOR SECOND FLOOR WITH FIRE PROTECTION.

NOTE:

- 1. SEE ARCHITECTURAL PLANS FOR FIRE RATED WALLS. PROVIDE FIRE PUTTY PADS ON ALL OUTLET AND DEVICES BOXES IN RATED WALLS.
- 2. FIRE ALARM DEVICES SHOWN AS REFERENCE. COORDINATE WITH OWNERS FIRE ALARM CONTRACTOR FOR CONDUIT ROUTING AND BOX LOCATIONS.

10/17/2014 10:57:31 AM - P:\IER11740\200-11740-10003\CAD\SHEETFILES\TREATMENT PLANT\WTP-E 2407 ELECTRICAL PLAN - MAIN PROCESS BUILDING.DWG - CALZARETTA, TIMOTHY

TETRA TECH

BID SET

HUNTSVILLE UTILITIES

SOUTHEAST WATER TREATMENT PLANT

ELECTRICAL PLAN -

MAIN PROCESS 1ST FLOOR

Project No.:

200-11740-10003

Designed By:

CSW

Drawn By:

TAC

Checked By:

DAB

E-2407

Copyright: Tetra Tech

Bar Measures 1 inch