
FROM LINE XX (24V+)
LINE NO.
(24V -)
SIEMENS DQ 16x240VDC/0.5A SLOT: 04
1 IN 0
LC-8 BUILDING LIGHTING ON/OFF
2 IN 1
LC-8 SITE LIGHTING ON/OFF
3 IN 2
GEN #1 COOLING WATER PUMP RUN COMMAND
4 IN 3
GEN #1 RADIATOR FAN RUN COMMAND
5 IN 4
SPARE
6 IN 5
SPARE
7 IN 6
SPARE
8 IN 7
SPARE
9
10
11 IN 8
SPARE
12 IN 9
SPARE
2 IN10
SPARE
14 IN11
SPARE
15 IN12
SPARE
16 IN2
SPARE
17 IN14
SPARE
18 IN15
SPARE
19
20
CR
24V +
24V -
SIEMENS AI 8xU/I/RTD/TC ST SLOT: 05
120VAC
RCP3 TE-1
RCP3 TTI-1
70 LE-3
70 LIT-3
FIBER
CURRENT
L
N
XXX XXX
1 IN 0
2 IN 0
3 IN 0
4 IN 0
5 IN 1
6 IN 1
7 IN 1
8 IN 1
9 IN 2
10 IN 2
11 IN 2
12 IN 2
13 IN 3
14 IN 3
15 IN 3
16 IN 3
17
18
19
20
21 IN 4
22 IN 4
23 IN 4
24 IN 4
25 IN 5
26 IN 5
27 IN 5
28 IN 5
29 IN 6
30 IN 6
31 IN 6
32 IN 6
33 IN 7
34 IN 7
35 IN 7
36 IN 7
WTP-RCP-3 PANEL TEMPERATURE (32-120 F)
OUTFALL FLOW RATE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SIEMENS AQ 4xU/I ST SLOT: 06
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE
SPARE