

**SARASOTA COUNTY GOVERNMENT
PROCUREMENT**

1660 Ringling Blvd., 3rd Floor • Sarasota, Florida 34236
Telephone 941-861-5266 • Fax 941-861-5129

BID #202050MN
Peace River Water Main Interconnect

ADDENDUM NO. 2

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the Bid. Items not referenced herein remain unchanged, including the response date.

Part I - Pertaining to the Solicitation Package:

Added Sheet Identification Sheet Number E-01
Added Sheet Identification Sheet Number E-02
Added Sheet Identification Sheet Number E-03
Added Sheet Identification Sheet Number E-04
Added Sheet Identification Sheet Number E-05
Added Sheet Identification Sheet Number I-01
Added Sheet Identification Sheet Number I-02
Added Sheet Identification Sheet Number I-03
Revised Sheet Identification Sheet Number 76

Part II – Pertaining to the Technical Specifications / Scope of Work

N/A

Part III – Responses to Questions:

1. **Question:** The Electrical and Instrumentation plans are missing (E-01-E05)(I-01-I-03) from the bid set. Please issue at your earliest convenience.

Answer: See Identification Sheet Numbers E-01 through E-05, I-01 through I-03 and 76.

2. **Question:** Who is responsible for density testing?

Answer: See Section 02222 – Trenching, Compacting, and Backfilling.

3. **Question:** What is the billing rate for construction water, including for use with chlorinating and testing of the 30” WTM?

Answer: Please contact Sarasota County Public Utilities at 941-861-6790 for this information.

4. **Question:** Please clarify where seed is acceptable, and provide quantities for both sod & seed. This will allow all potential bidders to provide comparable proposals.

**SARASOTA COUNTY GOVERNMENT
PROCUREMENT**

1660 Ringling Blvd., 3rd Floor • Sarasota, Florida 34236
Telephone 941-861-5266 • Fax 941-861-5129

Answer: See Section 02400 – Seeding and Sodding. Seeding and sodding is incidental to the installation of the pipe, therefore, no quantities are provided.

5. **Question:** Will swabbing and visual inspection be acceptable for the existing watermain diversions, or will full pressure testing/chlorinating/DOH clearance be required?

Answer: Please refer to FAC 62-555.520(c) for types of work that do not require Florida Department of Environmental Protection (FDEP) construction permits. Per FAC 62-555.345, potable water system components that are not permitted through FDEP do not need Department approval or clearance to be placed in permanent operation.

6. **Question:** Please confirm all location of the double thrust collars, and revise the detail as required for smaller diameter pipe.

Answer: See Revised Sheet Identification Sheet 76. Reverse thrust blocks are to be used in all areas as referenced in the Bid Plans and for any crossings of unrestrained pipe.

7. **Question:** Reference specifications Section 02660, page 2 of 4, par. 3.04, sub-par. B, is installing locator tape and tracing wire applicable only to PVC pipe or will the ductile iron pipe have to have these as well?

Answer: All pipe will require tracer wire as stated in Section 02660 – Piping-General.

8. **Question:** Reference specifications Section 02660, page 1 of 4, par. 3.01, INSPECTION, who is responsible for the cost to get a County representative to the production facility for the in plant inspection of pipe and or fittings?

Answer: The County reserves the right to inspect pipe or fittings during production. The Contractor is not responsible for this cost.

9. **Question:** Reference specifications Section 02660, page 1 of 4, par. 3.01, INSPECTION, production of pipe and production of fittings do not normally occur at the same facility and if an in-plant inspection is required for both types of materials more costs will be incurred for transportation and possibly lodging. Please clarify who will be responsible for transportation and lodging costs and if both types of materials will require in-plant inspection.

Answer: The County reserves the right to inspect the selected pipe or fittings during production. The Contractor is not responsible for this cost.

**SARASOTA COUNTY GOVERNMENT
PROCUREMENT**

1660 Ringling Blvd., 3rd Floor • Sarasota, Florida 34236
Telephone 941-861-5266 • Fax 941-861-5129

By submitting a response, offerors acknowledge receipt of any and all issued addenda, and agree to the provisions of each.

Approved by County:

Carmen Gomez

Digitally signed by Carmen
Gomez
Date: 2020.09.04 16:15:30 -04'00'

signature

Carmen Gomez, Procurement & Contracts Specialist

Melissa Neel

Digitally signed by Melissa Neel
Date: 2020.09.04 14:34:29 -04'00'

signature

Melissa Neel, Procurement & Contracts Specialist

Ron Shaffalo

Digitally signed by Ron Shaffalo
Date: 2020.09.04 14:39:32 -04'00'

signature

Ron Shaffalo, Project Manager