



PEACHTREE CREEK SOUTH FORK
RELIEF STORAGE AND PUMPING STATION

CITY OF ATLANTA

DEPARTMENT OF WATERSHED MANAGEMENT

REV	DATE	REVISION DESCRIPTION
0	10/28/12	300 PERCENT BID PACKAGE

THIS LINE IS ONE INCH LONG WHEN PLOTTED FULL SCALE

THIS DRAWING MUST BE USED IN CONJUNCTION WITH THE APPLICABLE OR GOVERNING TECHNICAL SPECIFICATIONS AND OTHER CONTRACT DOCUMENTS.

PROJECT NO: FC-6260
DATE: OCTOBER 2012

RESP PROF: KCV DESIGNER: WHP CHECKER: BLB

SHEET TITLE
INSTRUMENTATION
07 - JET MIXING PUMP STATION
EQUALIZED FLOW
RETURN PUMP
P&ID

NOTES:
1. EQUALIZATION DRAINAGE PUMPS (P-534/535) SHALL SHUT DOWN ON LOW MOTOR CURRENT AFTER PUMP START TO DETECT WHEN THE EQUALIZATION TANK RETURN PIPING HAS BEEN DRAINED.

SHEET NO. I-105 REV. 0